



Infrastructure Technology

Manuf. & Materials Technology, 14 Julius Ave (Riverside Corp. Park), North Ryde, NSW, 2113, Australia
Telephone: 61 2 9490 8252 Facsimile: 61 2 9490 5777 Email: tiles@csiro.au Web: http://www.cmse.csiro.au

Registered Testing Authority - CSIRO

20 October 2014

Our Ref. ES13 / 2235 03/0212

TEST REPORT No. SY7191

Requested by: **HOMEMIRUS PTY LTD**
4 Naughton Street
Greenacre
NSW 2190

on (date): 24 September 2014
Manufacturer: Kronoswiss
Product Desc.: Laminate flooring

Sampling details:
Where: Delivered
Date: 25 September 2014
By whom: Courier
How (methods): N/A

The results reported relate only to the sample(s) tested and the information received. No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision. CSIRO cannot accept responsibility for deviations in the manufactured quality and performance of the product. While CSIRO takes care in preparing the reports it provides to clients, it does not warrant that the information in this particular report will be free of errors or omissions or that it will be suitable for the client's purposes. CSIRO will not be responsible for the results of any actions taken by the client or any other person on the basis of the information contained in the report or any opinions expressed in it. The reproduction of this test report is only authorised in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction.

This test report consists of 4 pages

SUMMARY OF SLIP RESISTANCE TESTS PERFORMED:

		Result	Class
AS 4586:2013	Slip resistance classification of new pedestrian surface materials Appendix A: WET Pendulum (Slider 96):		
	Mean SRV:	39	P3 (X*)
AS 4586:2013	Slip resistance classification of new pedestrian surface materials, Appendix D: OIL-WET Ramp		
	Corrected mean overall acceptance angle:	9°	R 9
	(*) = AS 4568:2004 classification		

In order to interpret the classifications, please refer to Standards Australia Handbook 198, An Introductory Guide to the Slip Resistance of Pedestrian Surface Materials, which recommends minimum classifications for a wide variety of locations.

It is important to realise that test results obtained on unused factory-fresh samples may not be directly applicable in service, where proprietary surface coatings, contamination, wear and subsequent cleaning all influence the behaviour of the pedestrian surface.



REPORT NO: SY7191
ISSUE DATE: 20 October 2014
MANUFACTURER: Kronoswiss
PRODUCT DESC: Laminate flooring

SLIP RESISTANCE CLASSIFICATION OF NEW PEDESTRIAN SURFACE MATERIALS

WET PENDULUM TEST METHOD

TEST CARRIED OUT IN ACCORDANCE WITH
AS 4586:2013 (Appendix A)

Test Date: 14 October 2014

RESULTS: Location: North Ryde Slip Resistance Laboratory Slider used: 96
Sample: Unfixed Conditioned with grade P400 paper, dry
Cleaning: Acetone
Temperature: 23°C

Pendulum Friction Tester: Stanley (S/N: 7829, calibrated 15/04/2014)
Test conducted by: Babak Navak

	Specimen				
	1	2	3	4	5
Last 3 swings (BPN)	37	40	40	37	41
	36	40	40	37	40
	36	40	40	36	40
Averages	36	40	40	37	40

Mean SRV : 39

CLASS : **P3 (X*)**

(*) = AS 4568:2004 classification

Where products are to be used in wet barefoot areas, it is more appropriate to test to Appendix C of AS 4586 (which is technically equivalent to DIN 51097).



REPORT NO: SY7191
ISSUE DATE: 20 October 2014
MANUFACTURER: Kronoswiss
PRODUCT DESC: Laminate flooring

Page 3 of 4

SLIP RESISTANCE CLASSIFICATION OF NEW PEDESTRIAN SURFACE MATERIALS

OIL-WET RAMP TEST METHOD

TEST CARRIED OUT IN ACCORDANCE WITH
AS 4586:2013 (Appendix D)

Test Date: 17 October 2014

Location: Slip Resistance Laboratory Test conducted by: GW, BN

Sample Fixed

Joint width: mm

Surface structure: Smooth
 Profiled
 Structured

RESULTS

Corrected mean overall acceptance angle: 9 °

Displacement space: not tested

CLASSIFICATION:

Slip Resistance Assessment Group:

R 9

Displacement Space Assessment Group:

-

Test shoe used: Lupos Picasso



Infrastructure Technology

Manuf. & Materials Technology, 14 Julius Ave (Riverside Corp. Park), North Ryde, NSW, 2113, Australia
Telephone: 61 2 9490 8252 Facsimile: 61 2 9490 5777 Email: tiles@csiro.au Web: <http://www.cmse.csiro.au>

REPORT NO: 7191
ISSUE DATE: 20 October 2014
MANUFACTURER: Kronoswiss
TILE DESC: Laminate flooring

Page 4 of 4

Date and Place 20 October 2014, North Ryde, NSW

Name, Title and Digital Signature:



BABAK NAVAK
Materials Scientist
Tel: 61 2 94908252
Fax: 61 2 94905777
Email: Babak.Navak@csiro.au
